



ROANOKE COUNTY

Purchasing Division

5204 Bernard Drive, Suite 300F, P.O. Box 29800
Roanoke, Virginia 24018-0798
TEL: (540) 772-2061 FAX: (540) 772-2074

Kate Hoyt, Buyer
5204 Bernard Drive SW, Suite 300 F
Roanoke VA 24018
(540) 283-8149
(540) 561-2829 – Fax
khoyt@roanokecountyva.gov

August 8, 2019

IFB # 2020-008 Walking Trail of Lights at Roanoke County's Explore Park

ADDENDUM NO. 2

Answers to Questions Received

Due Date & Time:
August 16, 2019, 2:00 PM
(Local Prevailing Time)

IFB # 2020-008
EXPLORE PARK WALKING TRAIL OF LIGHTS
ADDENDUM NO. 2

1. Answers to Vendor Questions – Please see below for a list of questions received from interested parties, and the answers provided by the County as we are able.

a. What are working hours?

8:00 am to 5:00 pm, Monday through Saturday. No work is to be performed on Sundays, unless authorized.

b. If the trail goes over 6 feet wide in places, will that be an issue? It's hard to get a machine smaller than a 6'-7' bucket.

6-7' trail width is acceptable. We will not allow an 8' trail, which allows for vehicle access.

c. Please provide clarification regarding the wiring to be installed from the 600 amp MDP panel to each of the 5 branch panels. The drawings show installing (2) 4/0 conductors and (1) #2 ground wire to each of the 5 panels. That is not sufficient unless you are only installing 120 volts to each panel instead of 240 volts.

The conductors should be (3) 4/0 conductors and (1) #2 ground.

d. Please clarify regarding the proposed wiring from the 600 amp service disconnect to the 600 amp MDP panel. The wiring shown on the drawings is not sufficient to carry the 600 amp MDP panel per code.

Service conductors should be 2 sets (3-350 MCM, 1 1/10 Ground, 3" conduit).

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK