



ROANOKE COUNTY

Purchasing Division

5204 Bernard Drive, Suite 300-F, P.O. Box 29800
Roanoke, Virginia 24018-0798
TEL: (540) 772-2061 FAX: (540) 772-2074

August 26, 2021

ADDENDUM NO. 2 TO ALL BIDDERS/OFFERRORS:

Reference – IFB # 2022-015

Description: Brambleton Recreation Center Boiler Replacement

Issue Date: August 18, 2021

Proposal Due: August 31, 2021

The above Project is hereby changed as addressed below:

1. Response to bidder's request for specifications of the 3-way control valve:
The three way mixing valve shall be sized by the control manufacturer and shall have flanged connections. Valve packing shall be reinforced Teflon. Maximum allowable pressure drop shall be 5 ft. water column. Valve bodies shall have minimum ratings of 125 psig water service. The body shall be of high grade cast red brass with the upper seat machined integral with the bottom cap.

Note: A signed acknowledgment of this addendum must be received at the location indicated on the original solicitation either prior to the proposal due date or attached to your proposal. Signature on this addendum does not substitute for your signature on the original proposal/bid document. The original proposal/bid document must be signed.

Thank you,

Kate Hoyt

Phone: (540) 283-8149

KHoyt@roanokecountyva.gov

Sign Name:

Print Name:

Name of Firm:

Date: