



ROANOKE COUNTY

Purchasing Division

5204 Bernard Drive, Suite 300-F, P.O. Box 29800
Roanoke, Virginia 24018-0798
TEL: (540) 772-2061 FAX: (540) 772-2074

September 17, 2021

ADDENDUM NO. 1 TO ALL BIDDERS/OFFERRORS:

Reference – IFB # 2022-030

Description: Fire Alarm Control Panel Replacements

Issue Date: September 16, 2021

Proposal Due: October 14, 2021

The above Project is hereby changed as addressed below:

1. Clarification to Specifications: The following additional information is hereby offered in response to vendor inquiry.
 - a. Manufacturer and model numbers of existing panels: both existing panels are Simplex 4020.

Note: A signed acknowledgment of this addendum must be received at the location indicated on the original solicitation either prior to the proposal due date or attached to your proposal. Signature on this addendum does not substitute for your signature on the original proposal/bid document. The original proposal/bid document must be signed.

Thank you,

Kate Hoyt

Phone: (540) 283-8149

KHoyt@roanokecountyva.gov

Sign Name:

Print Name:

Name of Firm:

Date: