



ROANOKE COUNTY
Purchasing Division
5204 Bernard Drive, Suite 300-F
P.O. Box 29800 Roanoke, Virginia 24018-0798
TEL: (540) 772-2061 FAX: (540) 772-2074

September 6, 2024

Addendum No. 2 To All Bidders/Offerors:

Reference: IFB # 2025-017
Description: Dry Fire Suppression Systems Testing, Inspections and Cleaning
For Roanoke County and Western Virginia Regional Jail
Issue Date: 8/5/24
Proposal Due: 9/18/24

Questions received from potential bidders regarding this solicitation, and their answers, are below.

Note: A signed acknowledgment of this addendum must be received at the location indicated on the original solicitation either prior to the proposal due date or attached to your proposal.

Signature on this addendum does not substitute for your signature on the original proposal/bid document. The original proposal/bid document must be signed.

Q1: What size is each hood to help with proving an accurate quote for the cleaning?

- The hood at Brugh Tavern at Explore Park is 13' long and 3' deep.
- The hood at the County Jail is 18 feet by 5 feet.
- The hood at Bent Mountain Community Center is
- The hoods at Western Virginia Regional Jail are

Q2: How many fusible links are in each hood suppression system?

- The system at Brugh Tavern at Explore Park has five total fusible links two {2} 360° and three {3} 500° degree links)
- The system at the County Jail has four (4) links.
- The system at Bent Mountain Community Center has 2 fusible links
- The hoods at Western Virginia Regional Jail have a total of 19 fusible links

Continued

Q3: Are you wanting service rates for the hood suppression service? Or fire alarm services for the FM-200 systems?

We are requesting pricing for Testing, Inspections and Cleaning of Dry Fire Suppression Systems, specifically FM-200 systems, Ansul Hood Systems and Ansul Fire Extinguishers. We are **not** requesting *fire alarm* services at this time.

Q4: Do the FM-200 systems have their own individual releasing panel or are they controlled by one releasing panel?

All FM-200 systems are on a separate panel.

Sign Name:

Print Name:

Name of Firm:

Date: